


# CITY OF ABERDEEN BUILDING DEPARTMENT

BOB WAITE (Ext. 3214)  
RAY OLSON (Ext. 3220) MATT ANGLESEY (Ext. 3221)  
200 EAST MARKET STREET, ABERDEEN, WA 98520-5207  
FAX (360) 537-3350

## LOCATION OF SMOKE DETECTORS Within Dwelling Units



✱ Where the ceiling height of a **room** open to the hallway serving the bedrooms exceeds that of the hallway by **24 inches or more**, smoke detectors shall be installed in the hallway and in the adjacent room. If ceiling is vaulted or sloped detector shall be within 3' on a horizontal plane of the highest part of ceiling. Detectors shall be installed in accordance with the approved manufacturer's instructions.

**As per Manufacture's instructions smoke detectors shall not be located within 10 feet of a bathroom door. (A photoelectric detector can be used if less than 10 feet)**